

an ISO 9001-2008 certified company

Regd. Off.: Unit No. 1, Riddhi Siddhi, Corporate Park, V. N. Purav Marg, (Sion Trombay Road), Chembur, Mumbai - 400 071. MH, India.

Tel.: +91 - 22 - 4232 4121, 2529 9990,

Email: office@easternpetroleum.in, Web:www.easternpetroleum.in CIN NO:U24100MH1964PTC012931

PRODUCT DATA SHEET

PRODUCT:	EASTTO TRANSFORMER OIL 335
INTRODUCTION:	EASTTO TRANSFORMER OIL 335 having excellent insulating properties, good oxidation stability, low volatility and resistance to sludge formation. EASTTO TRANSFORMER OIL 335 is free from Acid, Alkali and Corrosive sulphur and excellent demulsibility characteristic.
APPLICATION:	Recommended for use in Electrical Capacitors, High voltage switches Circuit Breakers, Transformers, Electrical parts, Fluorescent lamp ballasts.







Recommended for use in Capacitors, Circuit Breakers and Transformers.

PERFORMANCE LEVEL: Meets IS 335-1993 (Reaffirmed 2005) specification.

TYPICAL PROPERTIES:

CHARACTERISTICS	EASTTO TRANSFORMER OIL 335
Density at 30 °C	0.890
Flash Point, °C	140
Pour Point ^o C.	- 6
Kinematic Viscosity at 27°C, cst	27
Breakdown Voltage, new unfiltered / after filtration	30 / 60
Corrosive Sulphur	Non-corrosive
Oxidation Stability at 100°C, 164 Hrs. a) Total Acidity b) Sludge	a) 0.4 b) 0.1
Water Content, ppm	50
Presence of Oxidation Inhibitor	Nil

PACKING: 210 Litres Drums Date of issue: 10.11.2014 Date of revision: 11.08.2016 1st Revision: 29.05.2019 (CK)

PDS No. 30700

These Characteristics are typical of current production while future production will confirm to **EASTERN PETROLEUM PVT. LTD.** Specification variation in these characteristics may occur.



an ISO 9001-2008 certified company

Regd. Off.: Unit No. 1, Riddhi Siddhi, Corporate Park, V. N. Purav Marg, (Sion Trombay Road), Chembur, Mumbai - 400 071. MH, India. Tel.: +91 - 22 - 4232 4121, 2529 9990,

Email: office@easternpetroleum.in, Web:www.easternpetroleum.in CIN NO:U24100MH1964PTC012931